

WARNING

Activation of the Oxygen Sensor Indicates Potential Oxygen Deficient Atmosphere

- Leave the laboratory immediately.**
- Activate the Emergency Ventilation Button if it is available.**
- Report to the Security Control Center by dialing 8999.**